

CENTRE FOR PROFESSIONAL AND ADVANCED STUDIES ,  
GANDHINAGR P.OKOTTAYAM Phone 0481 2595478

No.2864/2023/CPASHO

Dated: 19.09.2023

QUOTATION NOTICE

Competitive quotations are invited for the supply of 2 KVA /72 VDC UPS with Online Double Conversion, inbuilt isolation Transfromer, High Frequency IGBT , DSP and Dual microprocessor controlled system, Nominal input voltage-170-270 VAC, single Phase Input single Phase output and dedicated Earth, Static Bypass Fcacity, Nominal Input frequency-50 HZ+/-2Hz Permissible input frequency variation +/- 5% Input pwer factor-0.9, Input current Distortion-I-THD- <=5% Output power -2 kVA/1800 W, Output power factor-0.8 lagging or better, Nominal output voltage-230 V AC Single phase, Output voltage regulation-+/-1% , Output voltage distortion for 100% load and <+2% at linear load and 3% at nonlinear load. Nominal output frequency-50 Hz, Output frequency tolerance +/- 0.05%. UPS efficiency ->90% , LED/LCD Display for -Mains on , Inverter on, Battery Low , Over load Load Percentage, Common Alarm- Battery low, Pre-alarm, Trip, Output short circuit protection , Output over/inder volotage, Battery over temperatutre alarm - at DPS, SME, Thalappady. (on Buy Back Scheme)

**Last date of receipt of quotations : Till 2.00 pm on 25.09.2023**

**Date of opening of quotations:2.30 pm on 25.09.2023**

General Conditions

1. The quotations can be submitted as soft copy / hard copy. Soft copy shall be submitted via email **cpaspurchase@cpas.ac.in** . Hard copy shall be send to DIRECTOR, CENTRE FOR PROFESSIONAL AND ADVANCED STUDIES, GANDHINAGAR P.O , KOTTAYAM 686008.
2. The price quoted should be **inclusive** of all taxes, loading/ unloading charges, transmission charges etc
3. Acceptance of quotation and issue of supply order will be based on the discount offered and technical aspects as well.
4. The Equipment shall be supplied within 20 days of the supply order.

Sd/-  
DIRECTOR  
CENTRE FOR PROFESSIONAL AND ADVANCED STUDIES

\* This is a computer system (Digital File) generated letter. Hence there is no need for a physical signature.